
# **WILDEN**<sup>®</sup>

Engineering
Operation &
Maintenance

**PS400** Plastic Pump



Where Innovation Flows

wildenpump.com





# TABLE OF CONTENTS

SECTION	1	CAUTIONS—READ FIRST!	1
SECTION	2	WILDEN PUMP DESIGNATION SYSTEM	2
SECTION	3	HOW IT WORKS—PUMP & AIR DISTRIBUTION SYSTEM	3
SECTION	4	DIMENSIONAL DRAWINGS	4
SECTION	5	PERFORMANCE	
		PS400 Plastic Rubber-Fitted	5
		PS400 Plastic EZ-InstallTPE-Fitted	
		PS400 Plastic Full-Stroke PTFE-Fitted	6
		Suction-Lift Curves	7
SECTION	6	SUGGESTED INSTALLATION, OPERATION & TROUBLESHOOTING	8
SECTION	7	DISASSEMBLY / REASSEMBLY	. 11
		Air Valve / Center Section Disassembly	. 14
		Reassembly Hints & Tips	
SECTION	8	EXPLODED VIEW & PARTS LISTING	
		PS400 Plastic	.20
SECTION	9	ELASTOMER OPTIONS	.22







## CAUTIONS—READ FIRST!



CAUTION: Do not apply compressed air to the exhaust port — pump will not function.



**CAUTION**: Do not over-lubricate air supply excess lubrication will reduce pump performance. Pump is pre-lubed.



#### **TEMPERATURE LIMITS:**

0000 . 0000	000F / 1000F
-29°C to 82°C	–20°F to 180°F
-12°C to 82°C	10°F to 180°F
-40°C to 82°C	-40°F to 180°F
−18°C to 93°C	0°F to 200°F
-51°C to 138°C	-60°F to 280°F
−18°C to 93°C	0°F to 200°F
-7°C to 107°C	45°F to 225°F
0°C to 79°C	32°F to 175°F
-12°C to 66°C	10°F to 150°F
-12°C to 107°C	10°F to 225°F
-29°C to 104°C	-20°F to 220°F
4°C to 137°C	40°F to 280°F
d 4°C to 93°C	40°F to 200°F
4°C to 104°C	40°F to 220°F
–40°C to 177°C	–40°F to 350°F
–40°C to 107°C	–40°F to 225°F
	-40°C to 82°C -18°C to 93°C -51°C to 138°C -7°C to 107°C 0°C to 79°C -12°C to 66°C -12°C to 107°C -29°C to 104°C 4°C to 137°C d 4°C to 93°C 4°C to 104°C -40°C to 177°C

<sup>1</sup>4°C to 149°C (40°F to 300°F) - 13 mm (1/2") and 25 mm (1") models only.

NOTE: Not all materials are available for all models. Refer to Section 2 for material options for your pump.



CAUTION: When choosing pump materials, be sure to check the temperature limits for all wetted components. Example: Viton® has a maximum limit of 177°C (350°F) but polypropylene has a maximum limit of only 79°C (175°F).



**CAUTION:** Maximum temperature limits are based upon mechanical stress only. Certain chemicals will significantly reduce maximum safe operating temperatures. Consult Chemical Resistance Guide for chemical compatibility and temperature limits.



**WARNING:** Prevent sparking — If static sparking occurs, fire or explosion could result. Pump, valves and containers must be grounded to a proper grounding point when handling flammable fluids and whenever discharge of static electricity is a hazard.



CAUTION: Do not exceed 8.6 bar (125 psig) air supply pressure.



**CAUTION:** The process fluid and cleaning fluids must be chemically compatible with all wetted pump components.



CAUTION: Do not exceed 82°C (180°F) air inlet temperature for Pro-Flo® SHIFT models.



CAUTION: Pumps should be thoroughly flushed before installing into process lines. FDA- and USDA-approved pumps should be cleaned and/ or sanitized before being used.



**CAUTION:** Always wear safety glasses when operating pump. If diaphragm rupture occurs, material being pumped may be forced out air exhaust. Plastic series pumps are made of virgin plastic and are not UV-stabilized. Direct sunlight for prolonged periods can cause deterioration of plastics.



**CAUTION**: Before any maintenance or repair is attempted, the compressed air line to the pump should be disconnected and all air pressure allowed to bleed from pump. Disconnect all intake, discharge and air lines. Drain the pump by turning it upside down and allowing any fluid to flow into a suitable container.



CAUTION: Blow out air line for 10 to 20 seconds before attaching to pump to make sure all pipeline debris is clear. Use an in-line air filter. A 5µ (micron) air filter is recommended.



NOTE: When installing PTFE diaphragms, it is important to tighten outer pistons simultaneously (turning in opposite directions) to ensure tight fit. (See torque specifications in Section 7.)



NOTE: PVDF pumps come standard from the factory with expanded PTFE gaskets installed in the diaphragm bead of the liquid chamber, in the T-section and in the ball and seat area. PTFE gaskets cannot be re-used. Consult for installation instructions during reassembly.



NOTE: Before starting disassembly, mark a line from each liquid chamber to its corresponding air chamber. This line will assist in proper alignment during reassembly.



**CAUTION:** Pro-Flo® SHIFT pumps do have a singlepoint exhaust option for submersible applications. Do not use standard Pro-Flo® SHIFT models in submersible applications.




**CAUTION**: Tighten all hardware prior to installation.



## WILDEN PUMP DESIGNATION SYSTEM

# **PS400 PLASTIC**

38 mm (1-1/2") Pump Maximum Flow Rate: 458 lpm (121 gpm)



### **MATERIAL CODES**

#### MODEL

PS400 = PRO-FLO® SHIFT

#### **WETTED PARTS/OUTER PISTON**

KK = PVDF/PVDF

KZ = PVDF/NO OUTER PISTON

PP = POLYPROPYLENE/ POLYPROPYLENE

PZ = POLYPROPYLENE/NO OUTER PISTON

#### **AIR CHAMBERS**

P = POLYPROPYLENE

#### **CENTER BLOCK**

P = POLYPROPYLENE

#### AIR VALVE

P = POLYPROPYLENE

#### **DIAPHRAGMS**

BNS = BUNA-N (Red Dot)

EPS = EPDM (Blue Dot) FWS = SANITARY WIL-FLEX™,

EZ-INSTALL [Santoprene®

(Two Orange Dots)]

NES = NEOPRENE (Green Dot) TSS = FULL-STROKE PTFE

W/SANIFLEX™ BACK-UP

TWS = FULL-STROKE PTFE

W/WIL-FLEX™ BACK-UP

VTS = VITON® (White Dot)

WWL= WIL-FLEXTM IPD [Santoprene®

(Orange Dot)]

ZGS = GEOLAST®, EZ-INSTALL

ZPS = POLYURETHANE, EZ-INSTALL ZSS = SANIFLEX<sup>TM</sup>, EZ-INSTALL

ZWS= WIL-FLEX<sup>TM</sup>, EZ-INSTALL

#### **VALVE BALLS**

BN = BUNA-N (Red Dot)

EP = EPDM (Blue Dot)

FS = SANIFLEX<sup>TM</sup> [Hytrel® (Cream)]

FV = SANITARY VITON® (Two White

Dots)
FW = SANITARY WIL-FLEX™

[Santoprene® (Two Orange

Dots)]

NE = NEOPRENE (Green Dot) PU = POLYURETHANE (Brown)

TF = PTFE (White)

VT = VITON® (Silver or White Dot)

WF = WIL-FLEX<sup>TM</sup> [Santoprene®

(Orange Dot)]

#### **VALVE SEATS**

K = PVDF

P = POLYPROPYLENE

#### **VALVE SEAT O-RINGS**

BN = BUNA-N

TV = PTFE ENCAP. VITON®
WF = WIL-FLEX (Santoprene®)

### **SPECIALTY CODES**

0100 Wil-Gard 110V

0102 Wil-Gard sensor wires ONLY

0103 Wil-Gard 220V

0320 Single-point exhaust

0502 PFA-coated hardware

0504 DIN flange

0506 DIN flange, PFA-coated

0604 DIN flange, Wil-Gard II™ 220 V

NOTE: Most elastomeric materials use colored dots for identification.


NOTE: Not all models are available with all material options.


Viton® is a registered trademark of DuPont Dow Elastomers.



### HOW IT WORKS—PUMP

The Wilden diaphragm pump is an air-operated, positive displacement, self-priming pump. These drawings show flow pattern through the pump upon its initial stroke. It is assumed the pump has no fluid in it prior to its initial stroke.





seat. Liquid is free to move past the inlet

valve ball and fill the liquid chamber (see




FIGURE 2 When the pressurized diaphragm, diaphragm A, reaches the limit of its discharge stroke, the air valve redirects pressurized air to the back side of diaphragm B. The pressurized air forces diaphragm B away from the center while pulling diaphragm A to the center. Diaphragm B is now on its discharge stroke. Diaphragm B forces the inlet valve ball onto its seat due to the hydraulic forces developed in the liquid chamber and manifold of the pump. These same hydraulic forces lift the discharge valve ball off its seat, while the opposite discharge valve ball is forced onto its seat, forcing fluid to flow through the pump discharge. The movement of diaphragm A toward the center of the pump creates a vacuum within liquid chamber A. Atmospheric pressure forces fluid into the inlet manifold of the pump. The inlet valve ball is forced off its seat allowing the fluid being pumped to fill the liquid chamber.





FIGURE 3 At completion of the stroke, the air valve again redirects air to the back side of diaphragm A, which starts diaphragm B on its exhaust stroke. As the pump reaches its original starting point, each diaphragm has gone through one exhaust and one discharge stroke. This constitutes one complete pumping cycle. The pump may take several cycles to completely prime depending on the conditions of the application.



shaded area).

# HOW IT WORKS—AIR DISTRIBUTION SYSTEM




The heart of the patented Pro-Flo® SHIFT Air Distribution System (ADS) is the air valve assembly. The air valve design incorporates an unbalanced spool with the small end of the spool being pressurized continuously while the large end of the spool is alternately pressurized, then exhausted to move the spool. The air valve spool directs pressurized air to one chamber while exhausting the other. The air forces the main shaft/diaphragm assembly to move to one side - discharging liquid on that side and pulling liquid in on the other side. When the shaft reaches the end of the stroke, the inner piston actuates the pilot spool, which controls the air to the large end of the air valve spool. The repositioning of the air valve spool routes the air to the other air chamber. The air control spool allows air to flow freely into the air chamber for the majority of each pump stroke, but it significantly restricts the flow of air into the air chamber when activated by the inner piston near the end of the each stroke.



# **DIMENSIONAL DRAWINGS**

# **PS400 Polypropylene**




### **DIMENSIONS**

ITEM	METRIC (mm)	STANDARD (inch)					
Α	476	18.8					
В	82	3.2					
С	360	14.2					
D	602	23.7					
E	131	5.2					
F	665	26.2					
G	677	26.6					
Н	48	1.9					
J	138	5.4					
K	345	13.6					
L	441	17.4					
M	348	13.7					
N	324	12.8					
Р	268	10.6					
R	176	6.9					
S	208	8.2					
T	12	0.5					
	DIN FLANC	GE .					
U	110 DIA.	4.3 DIA.					
V	150 DIA.	5.9 DIA.					
W	18 DIA.	0.7 DIA.					
	ANSI FLANGE						
U	98 DIA.	3.9 DIA.					
V	127 DIA.	5.0 DIA.					
W	16 DIA.	0.6 DIA.					

LW0195 REV. B

# **PS400 PVDF**



### **DIMENSIONS**

ITEM	METRIC (mm)	STANDARD (inch)			
А	471	18.5			
В	83	3.2			
С	358	14.1			
D	596	23.4			
Е	130	5.1			
F	659	25.9			
G	670	26.4			
Н	48	1.9			
J	137	5.4			
K	345	13.6			
L	441	17.3			
M	346	13.6			
N	319	12.6			
Р	264	10.4			
R	174	6.9			
S	205	8.1			
T	12	0.5			
	DIN FLANC	GE .			
U	110 DIA.	4.3 DIA.			
V	149 DIA.	5.9 DIA.			
W	18 DIA.	0.7 DIA.			
	ANSI FLAN	GE			
U	98 DIA.	3.9 DIA.			
V	127 DIA.	5.0 DIA.			
W	16 DIA.	0.6 DIA.			
		LW0196 REV. B			


### PERFORMANCE

# PS400 PLASTIC RUBBER-FITTED

<sup>1</sup>Displacement per stroke was calculated at 4.8 bar (70 psig) air inlet pressure against a 2.1 bar (30 psig) head pressure.

**Example:** To pump 204 lpm (54 gpm) against a discharge head of 2.8 bar (40 psig) requires 4.1 bar (60 psig) and 54 Nm<sup>3</sup>/h (32 scfm) air consumption.


Caution: Do not exceed 8.6 bar (125 psig) air supply pressure.



Flow rates indicated on chart were determined by pumping water.

For optimum life and performance, pumps should be specified so that daily operation parameters will fall in the center of the pump's performance curve.


# PS400 PLASTIC EZ-INSTALL TPE-FITTED



Displacement per stroke was calculated at 4.8 bar (70 psig) air inlet pressure against a 2.1 bar (30 psig) head pressure.

**Example:** To pump 310 lpm (82 gpm) against a discharge head of 2.1 bar (30 psig) requires 5.5 bar (80 psig) and 92 Nm<sup>3</sup>/h (54 scfm) air consumption.

Caution: Do not exceed 8.6 bar (125 psig) air supply pressure.



Flow rates indicated on chart were determined by pumping water.

For optimum life and performance, pumps should be specified so that daily operation parameters will fall in the center of the pump's performance curve.






# **PERFORMANCE**

# PS400 PLASTIC FULL-STROKE PTFE-FITTED

<sup>1</sup>Displacement per stroke was calculated at 4.8 bar (70 psig) air inlet pressure against a 2.1 bar (30 psig) head pressure.

**Example**: To pump 223 lpm (59 gpm) against a discharge head of 3.4 bar (50 psig) requires 5.5 bar (80 psig) and 75 Nm<sup>3</sup>/h (44 scfm) air consumption.

Caution: Do not exceed 8.6 bar (125 psig) air supply pressure.



Flow rates indicated on chart were determined by pumping water.

For optimum life and performance, pumps should be specified so that daily operation parameters will fall in the center of the pump's performance curve.






# SUCTION-LIFT CURVES

## PS400 PLASTIC SUCTION-LIFT CAPABILITY

Suction-lift curves are calibrated for pumps operating at 305 m (1,000') above sea level. This chart is meant to be a guide only. There are many variables that can affect your pump's operating characteristics. The number of intake and discharge elbows, viscosity of pumping fluid, elevation (atmospheric pressure) and pipe friction loss all affect the amount of suction lift your pump will attain.





### SUGGESTED INSTALLATION

Wilden pumps are designed to meet the performance requirements of even the most demanding pumping applications. They have been designed and manufactured to the highest standards and are available in a variety of liquid-path materials to meet your chemical-resistance needs. Refer to the performance section of this manual for an in-depth analysis of the performance characteristics of your pump. Wilden offers the widest variety of elastomer options in the industry to satisfy temperature, chemical compatibility, abrasion resistance and flex concerns.

The suction pipe size should be at least the equivalent or larger than the diameter size of the suction inlet on your Wilden pump. The suction hose must be non-collapsible, reinforced type as these pumps are capable of pulling a high vacuum. Discharge piping should also be the equivalent or larger than the diameter of the pump discharge which will help reduce friction losses. It is critical that all fittings and connections are airtight or a reduction or loss of pump suction capability will result.

INSTALLATION: Months of careful planning, study and selection efforts can result in unsatisfactory pump performance if installation details are left to chance.

Premature failure and long-term dissatisfaction can be avoided if reasonable care is exercised throughout the installation process.

LOCATION: Noise, safety and other logistical factors usually dictate where equipment will be situated on the production floor. Multiple installations with conflicting requirements can result in congestion of utility areas, leaving few choices for additional pumps.

Within the framework of these and other existing conditions, every pump should be located in such a way that six key factors are balanced against each other to maximum advantage.

ACCESS: First of all, the location should be accessible. If it's easy to reach the pump, maintenance personnel will have an easier time carrying out routine inspections and adjustments. Should major repairs become necessary, ease of access can play a key role in speeding the repair process and reducing total downtime.

AIR SUPPLY: Every pump location should have an air line large enough to supply the volume of air necessary to achieve the desired pumping rate. Use air pressure up to a maximum of 8.6 bar (125 psig) depending on pumping requirements.

For best results, the pumps should use a  $5\mu$  (micron) air filter, needle valve and regulator. The use of an air filter before the pump will ensure that the majority of any pipeline contaminants will be eliminated.

SOLENOID OPERATION: When operation is controlled by a solenoid valve in the air line, three-way valves should be used. This valve allows trapped air between the valve and the pump to bleed off which improves pump performance. Pumping volume can be estimated by counting the number of strokes per minute and then multiplying the figure by the displacement per stroke.

MUFFLER: Sound levels are reduced below OSHA specifications using the standard Wilden muffler. Other mufflers can be used to further reduce sound levels, but they usually reduce pump performance.

ELEVATION: Selecting a site that is well within the pump's dynamic-lift capability will assure that loss-of-prime issues will be eliminated. In addition, pump efficiency can be adversely affected if proper attention is not given to site location.

PIPING: Final determination of the pump site should not be made until the piping challenges of each possible location have been evaluated. The impact of current and future installations should be considered ahead of time to make sure that inadvertent restrictions are not created for any remaining sites.

The best choice possible will be a site involving the shortest and straightest hook-up of suction and discharge piping. Unnecessary elbows, bends and fittings should be avoided. Pipe sizes should be selected to keep friction losses within practical limits. All piping should be supported independently of the pump. In addition, the piping should be aligned to avoid placing stress on the pump fittings.

Flexible hose can be installed to aid in absorbing the forces created by the natural reciprocating action of the pump. If the pump is to be bolted down to a solid location, a mounting pad placed between the pump and the foundation will assist in minimizing pump vibration. Flexible connections between the pump and rigid piping will also assist in minimizing pump vibration. If quick-closing valves are installed at any point in the discharge system, or if pulsation within a system becomes a problem, a surge suppressor (SD Equalizer®) should be installed to protect the pump, piping and gauges from surges and water hammer.

If the pump is to be used in a self-priming application, make sure that all connections are airtight and that the suction lift is within the model's ability. **NOTE**: Materials of construction and elastomer material have an effect on suction-lift parameters. Please refer to the performance section for specifics.

When pumps are installed in applications involving flooded suction or suction-head pressures, a gate valve should be installed in the suction line to permit closing of the line for pump service.

Pumps in service with a positive suction head are most efficient when inlet pressure is limited to 0.5–0.7 bar (7–10 psig). Premature diaphragm failure may occur if positive suction is 0.7 bar (10 psig) and higher.

SUBMERSIBLE APPLICATIONS: Pro-Flo® SHIFT pumps can be used for submersible applications when using the Pro-Flo® SHIFT's single-point exhaust option.


ALL WILDEN PUMPS ARE CAPABLE OF PASSING SOLIDS. A STRAINER SHOULD BE USED ON THE PUMP INTAKE TO ENSURE THAT THE PUMP'S RATED SOLIDS CAPACITY IS NOT EXCEEDED.

**CAUTION:** DO NOT EXCEED 8.6 BAR (125 PSIG) AIR SUPPLY PRESSURE.





# SUGGESTED INSTALLATION



**NOTE:** In the event of a power failure, the shut-off valve should be closed, if the restarting of the pump is not desirable once power is regained.

AIR-OPERATED PUMPS: To stop the pump from operating in an emergency situation, simply close the shut-off valve (user-supplied) installed in the air supply line. A properly functioning valve will stop the air supply to the pump, therefore stopping output. This shut-off valve should be located far enough away from the pumping equipment such that it can be reached safely in an emergency situation.



# SUGGESTED OPERATION & MAINTENANCE

OPERATION: The Pro-Flo® SHIFT pumps are prelubricated and do not require in-line lubrication. Additional lubrication will not damage the pump; however, if the pump is heavily lubricated by an external source, the pump's internal lubrication may be washed away. If the pump is then moved to a nonlubricated location, it may need to be disassembled and re-lubricated as described in the DISASSEMBLY/ REASSEMBLY INSTRUCTIONS.

Pump discharge rate can be controlled by limiting the volume and/or pressure of the air supply to the pump. An air regulator is used to regulate air pressure. A needle valve is used to regulate volume. Pump discharge rate can also be controlled by throttling the pump discharge by partially closing a valve in the discharge line of the pump. This action increases friction loss which reduces flow rate. (See Section 5.) This is useful when the need exists to control the pump from a remote location. When the pump discharge pressure equals or exceeds the air supply pressure, the pump will stop; no bypass or pressure relief valve is needed, and pump damage will not occur. The pump has reached a "deadhead" situation

and can be restarted by reducing the fluid discharge pressure or increasing the air inlet pressure. Wilden Pro-Flo® SHIFT pumps run solely on compressed air and do not generate heat; therefore, your process-fluid temperature will not be affected.

MAINTENANCE AND INSPECTIONS: Since each application is unique, maintenance schedules may be different for every pump. Frequency of use, line pressure, viscosity and abrasiveness of process fluid all affect the parts life of a Wilden pump. Periodic inspections have been found to offer the best means for preventing unscheduled pump downtime. Personnel familiar with the pump's construction and service should be informed of any abnormalities that are detected during operation.

RECORDS: When service is required, a record should be made of all necessary repairs and replacements. Over a period of time, such records can become a valuable tool for predicting and preventing future maintenance problems and unscheduled downtime. In addition, accurate records make it possible to identify pumps that are poorly suited to their applications.

### TROUBLESHOOTING

#### Pump will not run or runs slowly.

- 1. Ensure that the air inlet pressure is at least 0.4 bar (5 psig) above startup pressure and that the differential pressure (the difference between air inlet and liquid discharge pressures) is not less than 0.7 bar (10 psig).
- 2. Check air inlet filter for debris (see SUGGESTED INSTALLATION).
- 3. Check for extreme air leakage (blow by) that would indicate worn seals/bores in the air valve, pilot spool and main shaft.
- 4. Disassemble pump and check for obstructions in the air passageways or objects that would obstruct the movement of internal parts.
- 5. Check for sticking ball check valves. If material being pumped is not compatible with pump elastomers, swelling may occur. Replace ball check valves and seals with proper elastomers. Also, as the check valve balls wear out, they become smaller and can become stuck in the seats. In this case, replace balls and seats.
- 6. Check for broken inner piston that will cause the air valve spool to be unable to shift.
- 7. Remove plug from pilot spool exhaust.

#### Pump runs but little or no product flows.

1. Check for pump cavitation; slow pump speed down to allow thick material to flow into liquid chambers.

- 2. Verify that vacuum required to lift liquid is not greater than the vapor pressure of the material being pumped (cavitation).
- 3. Check for sticking ball check valves. If material being pumped is not compatible with pump elastomers, swelling may occur. Replace ball check valves and seats with proper elastomers. Also, as the check valve balls wear out, they become smaller and can become stuck in the seats. In this case, replace balls and seats.

#### Pump air valve freezes.

 Check for excessive moisture in compressed air. Either install a dryer or hot-air generator for compressed air. Alternatively, a coalescing filter may be used to remove the water from the compressed air in some applications.

#### Air bubbles in pump discharge.

- 1. Check for ruptured diaphragm.
- 2. Check tightness of outer pistons (refer to Section 7).
- 3. Check tightness of fasteners and integrity of O-rings and seals, especially at intake manifold.
- 4. Ensure pipe connections are airtight.

#### Product comes out air exhaust.

- 1. Check for diaphragm rupture.
- 2. Check tightness of outer pistons to shaft.





# PUMP DISASSEMBLY

#### Tools Required:

- 9/16" Socket Wrench
- 9/16" Combination
   Wrench for Nuts
   Between Air Valve and
   Air Chambers
- 1-5/16" Socket Wrench for Outer Pistons
- Adjustable Wrench
- Vise equipped w/ soft jaws (such as plywood, plastic or other suitable material)

**CAUTION:** Before any maintenance or repair is attempted, the compressed air line to the pump should be disconnected and all air pressure allowed to bleed from the pump. Disconnect all intake, discharge and air lines. Drain the pump by turning it upside down and allowing any fluid to flow into a suitable container. Be aware of any hazardous effects of contact with your process fluid.

**NOTE:** Your specific pump model may vary from the configuration shown; however, pump disassembly procedure will be the same.




#### Step 1

Before starting disassembly, mark a line from each liquid chamber to its corresponding air chamber. This line will assist in proper alignment during reassembly.



Step 2

Using an appropriate-sized wrench, loosen the discharge manifold to the liquid chambers.




Step 3

Remove the discharge manifold to expose the valve balls and seats.



# PUMP DISASSEMBLY




### Step 4

Remove the discharge valve balls and seats from the liquid chambers and inspect for nicks, gouges, chemical attack or abrasive wear. Replace worn parts with genuine Wilden parts for reliable performance.



Step 5

Using an appropriate-sized wrench, loosen the inlet manifold from the liquid chambers.




#### Step 6

Remove the inlet manifold, valve balls, valve seats and valve seat O-rings. Inspect for nicks, gouges, chemical attack or abrasive wear.



#### Step 7

Remove valve seats and valve balls for inspection. Replace if necessary.



#### Step 8

Using an appropriate-sized wrench, remove the liquid chamber fasteners that secure the liquid chamber to the center section.

### PUMP DISASSEMBLY



Step 9

Remove the liquid chamber to expose the diaphragm and outer piston.



Step 10

Using two adjustable wrenches, remove the diaphragm assembly from the center section assembly.



Step 11

**NOTE**: Due to varying torque values, one of the following two situations may occur: 1) The outer piston, diaphragm and inner piston remain attached to the shaft and the entire assembly can be removed from the center section. 2) The outer piston, diaphragm and inner piston separate from the shaft which remains connected to the opposite side diaphragm assembly. Repeat disassembly instructions for the opposite liquid chamber. Inspect diaphragm assembly and shaft for signs of wear or chemical attack. Replace all worn parts with genuine Wilden parts for reliable performance.



Step 12

To remove diaphragm assembly from shaft, secure shaft with soft jaws (a vise fitted with plywood, plastic or other suitable material) to ensure shaft is not nicked, scratched or gouged. Using an adjustable wrench, remove diaphragm assembly from shaft.



### Tools Required:

- 3/16 Hex-Head Wrench
- 1/4" Hex-Head Wrench
- Snap-Ring Pliers
- O-Ring Pick

**CAUTION**: Before any maintenance or repair is attempted, the compressed air line to the pump should be disconnected and all air pressure allowed to bleed from the pump. Disconnect all intake, discharge and air lines. Drain the pump by turning it upside down and allowing any fluid to flow into a suitable container. Be aware of hazardous effects of contact with your process fluid.

The Wilden Pro-Flo® SHIFT plastic pumps utilize a revolutionary Pro-Flo® SHIFT air distribution system. Proprietary composite seals reduce the coefficient of friction and allow the Pro-Flo® SHIFT to run lube-free. The Pro-Flo® SHIFT air distribution system is designed to perform in on/off, non-freezing, non-stalling, tough-duty applications.



Step 1

Loosen the air valve bolts using an appropriate-sized hex wrench.



Step 2

Remove air valve bolts, muffler plate and air valve assembly to expose muffler gasket and air valve gasket. Replace if necessary.



Step 3

Remove air valve end cap to expose the large end of the air valve spool by lifting up on the air valve end cap once the bolts have been removed.



#### Step 4

Remove air valve spool from air valve body by threading one air valve bolt into the end of the spool and gently slide the spool out of the air valve body. Inspect seals for signs of wear and replace entire assembly, if necessary. Use caution when handling the air valve spool to prevent damaging seals.



#### Step 5

Remove pilot spool retaining snap ring on both sides of the center section using snap-ring pliers.



Step 6

Remove the air chamber bolts using an appropriate-sized wrench.



#### Step 7

Remove the air chamber and inspect the air chamber gaskets (2). Replace if necessary.



Step 8

With an O-ring pick, remove the O-ring from the modulator spool.



Step 9

Remove the pilot spool from the center section.



Step 10

Using an O-ring pick, gently remove the O-ring from the opposite side of the dimpled-end of the pilot spool. Check for nicks, gouges or other signs of wear; replace pilot spool assembly if necessary.



Step 11

Remove modulator spool from center section. Check for wear to spool or O-ring and replace if necessary.



Step 12

Remove and inspect the shaft bushings (2). Replace if necessary.



Step 13

Once the air chambers have been removed, the square air valve nuts (6) may be removed or replaced if necessary.




Step 14

Inspect the center block  $Glyd^{TM}$  rings (2) for wear. If replacement is necessary, use an O-ring pick to remove the used  $Glyd^{TM}$  rings then replace with genuine Wilden replacement parts.





# SINGLE-POINT EXHAUST PRO-FLO® SHIFT







Step 1

Remove pilot exhaust muffler in pilot bleed port located at the front of the center block. Install 1/4" NPT pipe plug (00-7010-08) into bleed port.

Step 2

Next, install an optional single-point exhaust gasket (04-2638-52). The single-point air valve gasket can be purchased as a spare part or included with the purchase of a new Pro-Flo® SHIFT pump.



### REASSEMBLY HINTS & TIPS

#### **ASSEMBLY:**


Upon performing applicable maintenance to the air distribution system, the pump can now be reassembled. Please refer to the disassembly instructions for photos and parts placement. To reassemble the pump, follow the disassembly instructions in reverse order. The air distribution system needs to be assembled first, then the diaphragms and finally the wetted path. Please find the applicable torque specifications on this page. The following tips will assist in the assembly process.

- Lubricate air valve bore, center section shaft and pilot spool bore with NLGI grade 2 white EP bearing grease or equivalent.
- Clean the inside of the center section shaft bore to ensure no damage is done to new shaft seals.
- A small amount of NLGI grade 2 white EP bearing grease can be applied to the muffler and air valve gaskets to locate gaskets during assembly.
- Make sure that the exhaust port on the muffler plate is centered between the two exhaust ports on the center section.
- Stainless-steel bolts should be lubed to reduce the possibility of seizing during tightening.

#### PRO-FLO® SHIFT MAXIMUM TORQUE SPECIFICATIONS

Description of Part	Torque		
Air Valve	5.1 N•m (45 in-lb)		
Air Chamber/Center Block	27.1 N•m (20 ft-lb)		
Liquid Chamber to Air Chamber	9.6 N•m (85 in-lb)		
Manifolds to Liquid Chamber	9.6 N•m (85 in-lb)		
Outer Pistons	47.5 N•m (35 ft-lb)		

#### Figure A



#### SHAFT SEAL INSTALLATION:

#### **PRE-INSTALLATION**

 Once all of the old seals have been removed, the inside of the bushing should be cleaned to ensure no debris is left that may cause premature damage to the new seals.


#### **INSTALLATION**

The following tools can be used to aid in the installation of the new seals:

Needle-Nose Pliers Phillips Screwdriver Electrical Tape

- Wrap electrical tape around each leg of the needle-nose pliers (heat shrink tubing may also be used). This is done to prevent damaging the inside surface of the new seal.
- With a new seal in hand, place the two legs of the needle-nose pliers inside the seal ring. (See Figure A.)
- Open the pliers as wide as the seal diameter will allow, then with two fingers pull down on the top portion of the seal to form kidney-bean shape. (See Figure B.)
- Lightly clamp the pliers together to hold the seal into the kidney shape. Be sure to pull the seal into as tight of a kidney shape as possible, this will allow the seal to travel down the bushing bore with greater ease.
- With the seal clamped in the pliers, insert the seal into the bushing bore and position the bottom of the seal into the correct groove. Once the bottom of the seal is seated in the groove, release the clamp pressure on the pliers. This will allow the seal to partially snap back to its original shape.
- After the pliers are removed, you will notice a slight bump in the seal shape. Before the seal can be properly resized, the bump in the seal should be removed as much as possible. This can be done with either the Phillips screwdriver or your finger. With either the side of the screwdriver or your finger, apply light pressure to the peak of the bump. This pressure will cause the bump to be almost completely eliminated.
- Lubricate the edge of the shaft with NLGI grade 2 white EP bearing grease.
- Slowly insert the center shaft with a rotating motion.
   This will complete the resizing of the seal.
- Perform these steps for the remaining seal.

SHAFT SEAL






NOTES




# **EXPLODED VIEW & PARTS LISTING**

# **PS400 PLASTIC**

EXPLODED VIEW



#### ALL CIRCLED PART IDENTIFIERS ARE INCLUDED IN REPAIR KITS







# EXPLODED VIEW & PARTS LISTING

# **PS400 PLASTIC**

PARTS LISTING

Item	Description	Qty.	PS400/PPPPP P/N	PS400/KKPPP P/N			
AIR DISTRIBUTION COMPONENTS							
1	Air Valve Assembly, Pro-Flo® SHIFT¹	1	04-2039-20	04-2039-20			
2	O-Ring, End Cap (-225, Ø1.859" x Ø.139")	2	04-2390-52-700	04-2390-52-700			
3	End Cap	2	04-2330-20-700	04-2330-20-700			
4	Screw, SHC, Air Valve (1/4"-20 x 4-1/2")	6	01-6000-03	01-6000-03			
5	Nut, Square (1/4"-20)	6	00-6505-03	00-6505-03			
6	Muffler Plate, Pro-Flo® SHIFT	1	04-3189-20	04-3189-20			
7	Gasket, Muffler Plate, Pro-Flo® SHIFT	1	04-3509-52	04-3509-52			
8	Gasket, Air Valve, Pro-Flo® SHIFT	1	04-2639-52	04-2639-52			
9	Center Block Assembly, Pro-Flo® SHIFT <sup>2</sup>	1	04-3129-20	04-3129-20			
10	Sleeve, Threaded, Center Block	4	04-7710-08	04-7710-08			
11	Removable Pilot Sleeve Assembly	1	04-3882-99 04-3882-99				
12	Pilot Spool Retaining O-Ring (-009, Ø.204" x Ø.070")	2	04-2650-49-700	04-2650-49-700			
13	Shaft Seal	2	08-3210-55-225	08-3210-55-225			
14	Shaft Bushing	2	08-3306-13	08-3306-13			
15	Gasket, Center Block Pro-Flo SHIFT	2	04-3529-56	04-3529-56			
16	O-Ring, (-210, Ø.734" x Ø.139")	2	04-3209-49	04-3209-49			
17	Air Control Spool	1	04-3858-03	04-3858-03			
18	Air Control Spool Retaining O-Ring (-114, Ø.612" x Ø.103")	2	04-3879-50	04-3879-50			
19	Air Chamber, Pro-Flo® SHIFT	2	04-3689-20	04-3689-20			
20	Washer, Flat (Ø.406" x Ø.875" x .125")	8	04-6741-03	04-6741-03			
21	Screw, HHC (3/8"-16 x 1-1/4")	8	04-6190-03	04-6190-03			
22	Retaining Ring	2	04-3890-03	04-3890-03			
23	Bushing Reducer 1-1/2" MNPT to 1" FNPT	1	04-6959-17	04-6959-17			
24	Muffler 1" MNPT	1	15-3514-99	15-3514-99			
25	Muffler 1/4" MNPT	1	04-3240-07	04-3240-07			
	WETTED PATH COMPONEN		0.02.00	0.02.00			
26	Chamber, Liquid	2	04-5005-20	04-5005-21			
27	Washer, Plain (Ø.406" x Ø.812" x .065")	32	04-6740-03	04-6740-03			
28	Screw, HHCS (3/8"-16 x 3-1/2")	16	04-6191-03	04-6191-03			
29	Nut, Hex Flange (3/8"-16)	16	04-6435-03	04-6435-03			
30	Screw, HHCS, (3/8"-16 x 1-3/4")	16	04-6181-03	04-6181-03			
31	Manifold, Discharge (ANSI)	1	04-5030-20	04-5030-21			
- 01	Manifold, Discharge (DIN)	1	04-5031-20	04-5031-21			
32	Manifold, Inlet (ANSI)	1	04-5090-20	04-5090-21			
UL	Manifold, Inlet (DIN)	1	04-5091-20	04-5091-21			
	GASKETS/VALVE BALLS/VALVE SEATS/V	<u>.</u>		04 3031 21			
33	Valve Ball	4	*	*			
34	Valve Seat	4	04-1125-20	04-1125-21			
35	Valve Seat O-Ring (-331, Ø2.225" x Ø.210")	4	*	*			
36	Manifold O-Ring (-340, Ø3.350" x Ø.210")	4	*	*			
30	FULL-STROKE RUBBER/TPE/PTFE/FSIPI		NENTS				
27	Shaft, Pro-Flo® Rubber Advanced		04-3811-03	UV-3811 U3			
37		1		04-3811-03			
38	Shaft Stud (1/2"-20 x 1.88")	2	08-6150-08	08-6150-08			
39	Inner Piston	2	04-3700-01-700	04-3700-01-700			
40	Diaphragm, Primary	2	*	*			
	Diaphragm, IPD Primary	2	*	*			
41	Diaphragm, Backup	2	*	*			
42	Outer Piston	2	04-4550-20-500	04-4550-21-500			

<sup>1</sup>Air Valve Assembly includes items 2 and 3 <sup>2</sup>Center Block Assembly includes items 10, 13, 14 and 16. BSPT to NPT Air Line Reducer Bushing (P/N 04-6950-23-702) is available upon request. 0504 Specialty Code = DIN Flange

\*Refer to Elastomer Chart.

All boldface items are primary wear parts.

LW0198 Rev. D





# ELASTOMER OPTIONS

## **PS400 Plastic**

MATERIAL	DIAPHRAGMS (2)	FULL-STROKE DIAPHRAGMS (2)	FULL-STROKE BACKUP DIAPHRAGMS (2)	EZ-INSTALL DIAPHRAGMS (2)	FULL-STROKE IPD DIAPHRAGMS (2)	VALVE BALLS (4)	VALVE SEATS (4)	VALVE SEAT O-RINGS (4)	MANIFOLD O-RINGS (4)
Polyurethane	N/A	N/A	N/A	04-1022-50	N/A	04-1080-50	N/A	N/A	N/A
Neoprene	04-1010-51	N/A	N/A	N/A	N/A	04-1080-51	N/A	N/A	N/A
Buna-N	04-1010-52	N/A	N/A	N/A	N/A	04-1080-52	N/A	08-1300-52-500	04-1371-52
Geolast®	N/A	N/A	N/A	04-1022-15	N/A	N/A	N/A	N/A	N/A
EPDM	04-1010-54	N/A	N/A	N/A	N/A	04-1080-54	N/A	N/A	N/A
Viton®	04-1010-53	N/A	N/A	N/A	N/A	04-1080-53	N/A	N/A	N/A
Saniflex™	N/A	N/A	04-1065-56	04-1022-56	N/A	04-1080-56	N/A	N/A	N/A
PTFE	N/A	04-1040-55	N/A	N/A	N/A	04-1080-55	N/A	N/A	N/A
PTFE Encap. (Viton®)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	08-1300-60-500	04-1371-60
FDA Wil-Flex™	N/A	N/A	04-1065-57	04-1022-57	N/A	04-1080-57	N/A	N/A	N/A
Wil-Flex™	N/A	N/A	N/A	04-1022-58	04-1031-58	04-1080-58	N/A	08-1300-58-500	04-1371-58
Polypropylene	N/A	N/A	N/A	N/A	N/A	N/A	04-1125-20	N/A	N/A
PVDF	N/A	N/A	N/A	N/A	N/A	N/A	04-1125-21	N/A	N/A

LW0198 Rev. D



NOTES



NOTES



### WARRANTY

Each and every product manufactured by Wilden Pump and Engineering, LLC is built to meet the highest standards of quality. Every pump is functionally tested to insure integrity of operation.

Wilden Pump and Engineering, LLC warrants that pumps, accessories and parts manufactured or supplied by it to be free from defects in material and workmanship for a period of five (5) years from date of installation or six (6) years from date of manufacture, whichever comes first. Failure due to normal wear, misapplication, or abuse is, of course, excluded from this warranty.

Since the use of Wilden pumps and parts is beyond our control, we cannot guarantee the suitability of any pump or part for a particular application and Wilden Pump and Engineering, LLC shall not be liable for any consequential damage or expense arising from the use or misuse of its products on any application. Responsibility is limited solely to replacement or repair of defective Wilden pumps and parts.

All decisions as to the cause of failure are the sole determination of Wilden Pump and Engineering, LLC.

Prior approval must be obtained from Wilden for return of any items for warranty consideration and must be accompanied by the appropriate MSDS for the product(s) involved. A Return Goods Tag, obtained from an authorized Wilden distributor, must be included with the items which must be shipped freight prepaid.

The foregoing warranty is exclusive and in lieu of all other warranties expressed or implied (whether written or oral) including all implied warranties of merchantability and fitness for any particular purpose. No distributor or other person is authorized to assume any liability or obligation for Wilden Pump and Engineering, LLC other than expressly provided herein.

#### PLEASE PRINT OR TYPE AND FAX TO WILDEN

PUMP INFORMATION			
Item #	Serial #		
Company Where Purchased			
YOUR INFORMATION			
Company Name			
Industry			
Name		Title	
Street Address			
City	State	Postal Code	Country
Telephone Fax E	E-mail		Web Address
Number of pumps in facility?	_ Number of W	/ilden pumps?	
Types of pumps in facility (check all that apply):   Diaphragm	n 🗌 Centrifu	ugal 🗌 Gear	Submersible Lobe
Other			
Media being pumped?			
How did you hear of Wilden Pump?	Trade Show	w Interr	net/E-mail Distributor
Other			

ONCE COMPLETE, FAX TO (909) 783-3440





# Where Innovation Flows

# **WILDEN**

PSG 22069 Van Buren St., Grand Terrace, CA 92313-5607 P: +1 (909) 422-1730 • F: +1 (909) 783-3440 wildenpump.com

PSG' reserves the right to modify the information and illustrations contained in this document without prior notice. This is a non-contractual document. 06-2017

Authorized PSG Representative:

Copyright ©2017, PSG°, A Dover Company